



SITE PLAN SYMBOLS

DISCONNECTION AREA

SLOPE ARROW

PLAN VIEW

DISCONNECTION NOTES

1. RUNOFF FROM DISCONNECTED DISCHARGES SHALL DRAIN IN A SAFE AND NON-EROSIVE MANNER THROUGH VEGETATED AREAS TO THE PROPERTY LINE OR SWALE.
2. THE LENGTH OF THE "DISCONNECTION" SHALL BE 10 FEET OR GREATER, WITH THE LENGTH BEING EQUAL TO OR GREATER THAN THE LENGTH OF THE IMPERVIOUS SURFACE. TURF MUST BE PERPETUALLY RESERVED AND MAINTAINED AS LUSH VEGETATION.
3. THE MAXIMUM IMPERVIOUS FLOW PATH SHALL BE 75 FEET.
4. DISCONNECTION AREAS SHALL BE LOCATED ON GRADUAL SLOPES LESS THAN 5%.

C:\Stormwater Management\SWM Standard Plan\Details\SR-102.01-Non-Rooftop.dwg

APPROVED 12/01/15
DATE

DIRECTOR, DEPT. OF PUBLIC WORKS

CHIEF OF ENGINEERING

SCALE:
NO SCALE

REVISIONS:

QUEEN ANNE'S COUNTY
DEPARTMENT OF PUBLIC WORKS

SINGLE LOT RESIDENTIAL ONLY

**NON-ROOFTOP DISCONNECTION
CREDIT DETAIL**

STANDARD NO. SW-102.01