



1. CHANNEL SHALL BE BRICK OR HAND FORMED CONCRETE MIN. THICKNESS OF 4".
SLOPE SIDES TO PIPE INVERT. MORTAR SHALL BE "TYPE S".
2. PROVIDE LIFT HOOKS IN UNEXPOSED SURFACES TO ACCOMMODATE FIELD PLACEMENT.
3. TOP OF INLET SHALL MATCH TOP OF CURB FOR ELEVATION.

SHARE1\CAD\ROAD STANDARDS\FINAL\INLET_MTD_106.02.DWG

APPROVED 1-3-03
DATE

[Signature]
ACTING
DIRECTOR, DEPT. OF PUBLIC WORKS

[Signature]
CHIEF ROADS ENGINEER

SCALE:
NO SCALE

REVISIONS:

QUEEN ANNE'S COUNTY
DEPARTMENT OF PUBLIC WORKS

**MOUNTABLE CURB
INLET**

STANDARD NO. RD-106.02